



Patterson-Kelley

Harsco

Established 1880

100 Burson Street
P.O. Box 458
East Stroudsburg, PA 18301 USA

Telephone: 570.421.7500

Fax: 570.421.8735

Web: www.patkelco.com

April 2, 2008

Dwight Hedgepath, Technical Director
Rhomar Water Management, Inc.
PO Box 229
Springfield, MO 65801

Please be advised that we have found Rhomar's chemical treatment system for multi-metal hydronic systems to be acceptable for use both our MACH and Thermific series boilers. The specific Rhomar products evaluated are as follows:

Hydro-Solve 9250	Cleaner
Pro-Tek AL	Scale Inhibitor
RhoGard	Inhibited Glycol

If you have questions or require additional information, please contact us at your convenience.

Regards,

Patterson-Kelley Co. (HARSCO)

A handwritten signature in black ink, appearing to read 'Chris Hurst'.

Chris Hurst
Regional Sales Manager

Mobile: 570-460-3335
Email: churst@patkelco.com